



General notes:

1. All the batteries cables should be 4/0 AWG.
2. Victron Quattro inverters must be used in a split phase setup. A MK3-USB is required to make those changes on a laptop.
3. The max. continuous power supplied per inverter is 2400W and 4800W a surge for a few seconds. Therefore, the max total power per split phase is 9600W or 40A @240VAC.
4. The battery cables to the Victron Power In and from the Victron Lynx to the inverters should be the same length!!!